

CERTIFICATE OF CONSTANCY OF PERFORMANCE

LGAI Technological Center, S.A. (APPLUS)
Notified Body Nr. 0370

No. **0370-CPR-3136**

In compliance with Regulation (EU) Nr.305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

SMOKE AND HEAT CONTROL SYSTEMS. VENTILATORS (FANS).

RANGE: **TUNNEL JET FAN AIR-J-F F400**

Placed on the market under the name of:

AIRONN Havalandirma Sanayi Anonim Şirketi

KARATEPE MAH. CUMHURİYET CADESSI MERA SOK. No. 13
KARTEPE / KOCAELİ (TURKEY)

And produced in the manufacturing plant:

KARATEPE MAH. CUMHURİYET CADESSI MERA SOK. No. 13
KARTEPE / KOCAELİ (TURKEY)

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 12101-3:2015

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 2nd November 2018 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body. It is confirmed on 17th March 2023.

The monitoring assessment will be done before 30th November 2023

Bellaterra, 17th March 2023


LGAI Technological Center, S.A.

Xavier Ruiz Peña
Managing Director, Product Conformity B.U.



This document is not valid without its technical annex, whose number coincides with the number of certificate

You can check the validity of this certificate on our website: www.appluslaboratories.com/certified_products

The manufacturer, after the completion of the conformity assessment procedures and the declaration of performance, may affix the CE Marking under his responsibility

