



EFFECTIS ERA AVRASYA TEST VE BELGELENDİRME A.Ş.
Dilovası OSB Mahallesi Firat Caddesi No: 18
Dilovası KOCAELİ/TÜRKİYE
www.effectis.com

TEST CERTIFICATE

Certificate No: EEA – 2000 – 0106

The related resistance to fire test was carried out at **Efectis Era Avrasya Test Laboratories** on 27.07.2020 in accordance with the EN 1366-10:2011+A1:2017 standard for the product as described below:

Single Compartment Smoke Control Damper “ADS-2020-1”

1400 x 1200 mm (w x h) – including the motor case

FIRE RESISTANCE CLASSIFICATION

E₆₀₀ 120 (V_{ed} – i↔o) S1000C₃₀₀AA Single

* The test is continued for 150 min and the product kept satisfying the classification above during this time.

Placed on the Market by

AIRONN HAVALANDIRMA SANAYİ A.Ş.

KARATEPE MAH. MERA SK. NO:13 KARTEPE KOCAELİ/TURKEY

And Produced In the Factory

AIRONN HAVALANDIRMA SANAYİ A.Ş.

KARATEPE MAH. MERA SK. NO:13 KARTEPE KOCAELİ/TURKEY

This test certificate is a declaration of the test results and does not represent any type approval or certification of the product. All details related to product specifications and field of application are described in the report **EEA-20-138**.

This certificate is initially valid until 20th August 2021 providing that no significant modifications are made in technical specification of the specimen and related test and classification standards.

Ali BAYRAKTAR
Laboratory Manager
20.08.2020

